



PREVENTATIVE MAINTENANCE CHECKLIST

Natural / Propane Gas Engine

1. Replace all spark plugs annually.
2. Change engine lubrication oil and oil filter annually.
3. Replace air filter.
4. Check battery charging system, alternator, starter, and governor.
5. Check entire unit for fuel and oil leakage.
6. Service battery(s); add water, clean posts, replace corrosion inhibiting pads if necessary
7. Remove all carbon and dust deposits from generator.
8. Conduct safety shutdown check and run generator.
(Check voltage, frequency, instruments and adjust carburetor and governor)
9. Test generator under available load from home* by performing an Automatic Transfer Switch test
10. Submit technician report to owner and advise on additional parts/labor required.

***Note: The testing of your generator under simulated power outage conditions is essential to ensuring that your standby power system operates in the event of an actual outage. This test will require access to the automatic switch gear and interrupting power to the home twice over a 10-15-minute period.

Please acknowledge your understanding of the need to perform this test by initialing here: _____

If access is denied or a simulated power outage is waived by the homeowner, FM Generator is unable to ensure reliability of the equipment. In this case, FM Generator may not be held responsible for service calls resulting from a failure to transfer or the generator failing to operate correctly in an emergency operation.